



SPMT commissioning status

Gioacchino Alex Anastasi,
Antonella Castellina

AugerPrime SDEU F2F meeting
04/06/2024

Summary

Total number of SPMT units to be installed : 1510

- ✓ 1477 already installed
- ✗ 33 missing (25 in forbidden areas, 8 due to problematic installation)
- ✓ only 16 SPMTs with hardware issues since beginning of the deployment.

See Antonella's slides at the [ORR SDEU session](#) for detailed information.

The SPMT commissioning mainly includes :

- HV setting and cross-calibration
(for the extension of the WCD signal dynamic range)
- inclusion in the SD reconstruction
- monitoring of
 - SPMTs units (from *SlowControl*)
 - small showers acquisition
 - SPMT cross-calibration

Reference GAP for
SPMT cross-calibration
[GAP2022_018](#)

Dynamic range

Automatic setting (see backup for details)

-> SPMT HV to reach $S_{\max} = 22,500 \text{ VEM}$ <-

Procedure successful
in almost all SPMTs !


~1% failure, due to:

- ▶ presence of a non-masked but malfunctioning LPMT
- ▶ (rarely) instabilities in the data acquisition

07/07/2023 : UUB-DAQ
software update including
the automatic HV setting


Maximum signal without saturation S_{\max} estimated using small showers data

S_{\max} (kVEM)




Performance of the cross-calibration


- SPMTs nicely working in ~80% of station
 - variation with temperature ($\sim 0.4\%/\text{ }^{\circ}\text{C}$) within expectations
- decrease in measured light for ~20% of SPMTs
 - seasonal behavior (see also next slides)



↓ Less light \Rightarrow larger cross-calibration factor β ↓





Stable cross-calibration (example LsId 433)




Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.





SPMT in a good station
 $\sigma[\beta]/\beta < 4\%$
 $\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}]$
 $\sim 10-12\%$

Deficit in the light at the SPMT (example Lsld 822)



Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.




When the light reaching the SPMT reduces...

$$\sigma[\beta]/\beta < 6\%$$

$$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 13-15\%$$


Evolution in time

Number of tanks with $S_{\max} \in [15, 30] \text{ kVEM}$



Generally good & stable SPMTs


Number of tanks with $S_{\max} > 30 \text{ kVEM}$



Reduction of light at the SPMT

- Clearly seasonal effect (even if its origin is not fully understood)
- Cross-calibration always performed
(effect on accuracy of the final calibrated signal to be studied)
- Monitoring of this issue under development


Issues with non-masked but malfunctioning LPMTs



- Non-masked but bad LPMTs spoil the cross-calibration in ~3% of stations ([link](#)).


✓ Issue mitigated in the [latest Offline tag](#) with additional checks during the SD rec.

- To be implemented : selection based on signal spectra from the small shower dataset.
- For better performances also the (new) standard quality cuts for UUB LPMTs are needed.



Modulations in zenith and azimuth

- ★ From simulated showers:
 - azimuth modulations due to the non-central SPMT location;
 - zenith modulations due to the differences in the PMT geometries.



- ★ Currently parameterized and corrected in SD rec. during the LDF fit.

SPMT corrected signal

$$S_{corrected} = S_{SPMT} / C(\theta, \phi)$$


$$C(\theta, \phi) = 1 + Z(\theta) + A(\theta)\cos(\phi - 30^\circ)$$

$$Z(\theta) = z_1 \sin^2 \theta$$

$$A(\theta) = a_1 \sin \theta$$

$$\text{with } z_1 = -0.056, a_1 = -0.0506$$

SPMT signal accuracy



SPMT signal (relative) accuracy:

- ❖ ~10% @ LPMTs saturation
- ❖ ~6% @ highest signals

★ Extrapolated maximum bias at highest signals: $(2.8 \pm 2.0)\%$

Relative SPMT signal accuracy

([GAP2022_018](#))

$$\frac{\sigma_{S_{SPMT}}}{S_{SPMT}} = \sqrt{a^2 + \frac{b^2}{S_{SPMT}}}$$

- ❖ evaluated using 1 month of small showers data from 300 SPMTs:

$$a = (5.8 \pm 1.1)\%$$

$$b = (1.8 \pm 0.2) VEM^{1/2}$$


- ✓ consistent results obtained with simulations of UHE p/Fe-initiated showers in UUB twin stations

- ✓ implemented in the Offline

Other Offline & reconstruction infos

- ❖ SD event **production v2r4** (which includes the SPMT cross-calibration) available starting from 03/08/2022.
- ❖ SPMT included in simulations (see *Offline call 24/04/2023*, [download](#)).
- ❖ SPMT signal integrated 5 bins (~42 ns) before the LPMTs start bin due to delay > 30 ns of the LPMTs (see *backup for more details*).
- ❖ Code for including SPMT signal in the LDF fit already implemented (see *Offline call 28/08/2023*, [download](#)) **but currently in the LDFFinder XMLs** `useSPMTSignal = false`.
- ❖ In the [latest Offline tag](#), the calibrated and corrected SPMT signal is stored in the standard ADST *PMTRecData*
`signal_spmt = station.GetPMTTraces(eTotalTrace,4).GetVEMSignal()`
where `station` is an ADST *SdRecStation* object.

SPMT monitoring



Monitoring of small showers
acquisition partially implemented
→ codes under ***augermonitoring***

- calculation of 1h-averages
- filling of the MonitSmallShowers table (see also slide in backup)
- **alarms under development**

“Hardware” (i.e. SlowControl) monitoring in common with the other components.

- alarms missing for all AugerPrime detectors
- should add check of SPMT I_{mon}/V_{mon} ratio

Conclusions and outlook

In the vast majority of the array, the SPMT is working and extending the signal dynamic range with optimal performances.

Work still needed to

- finalize the small showers' acquisition monitoring
- implement a monitoring of the cross-calibration procedure
- study the SPMT signal in the SD reconstruction, including:
 - ▶ switching from saturated LPMTs to SPMT
(currently implemented as discussed [here](#))
 - ▶ biases with respect to the current LDF parametrization
 - ▶ accuracy in the core determination
 - ▶ effect on S1000 → energy
 - ▶ ...

Final note : small showers can be used also for monitoring & commissioning of LPMTs (and SSD) given their rate of ~200 evts/h

Backup

Small showers acquisition

Small showers selection in each Local Station

Stream data every hour to CDAS

@ CDAS

- (i) decompress small showers data-stream
- (ii) storage into “monitoring-like” ROOT files

Data transfer to Lyon every day

@ Lyon (cca-in2p3)

Small showers analysis and β calculation

Calibration :

add β in SD data
during merging

Monitoring :

add values (daily)
to new DB table

Small showers stored by CDAS-DAQ in one
spmt_yyyy_mm_dd.root file per day with
data from ~00:00 to ~23:59 of dd/mm/yyyy
from the whole array (< 300 MB/day).

Small shower = T1 event selected as
(n-1)-fold coincidence among unmasked
LPMTs (tuning individual thresholds)

	Variables	Freq.
EVENT info	GPS time	~ 200/h (~ 400/h with a masked LPMT)
	event enumerator	
	AREA_PEAK_SATUR x 6 (LPMT1-2-3 / sPMT / SSD LG-HG)	
MUON info	GPS sec	~ 1 / min
	LPMT VEM charge x 3 (from histograms, custom process)	
	SSD MIP charge	
DAQ info	GPS sec	~ 1 / 5 min
	LPMTs masked status	
	HG/LG ratio x 3	
	LPMT threshold x 3	
	online VEM (peak) x 3	

Codes in the [SDEU/UUB/daq](#) and
[CDAS-DAQ](#) repositories

SPMT HV setting

GOAL : set the HV allowing to measure signals without saturation at least up to 20,000 VEM

Saturation determined by the FADC dynamic range

d.r. = 4095 - baseline ~ 3845 FADC counts

In first approximation

$$Q_{max} = AoP_{ref} \times d.r.$$

Thus, for the SPMT signal

$$S_{max} = AoP_{ref} \times d.r. \times \beta$$



where AoP_{ref} is the signal width and β the calibration factor

Procedure performed on-tank using small showers :

- β = harmonic mean of the S_{LPMTs} avg. / Q_{SPMT} signal ratio
- $AoP_{ref} = \langle AoP \rangle_{small\ showers}$
(conservative choice : width of signal in standard events larger than in small showers)

✓ Automatic procedure activated during July 2023
[code maintained](#) in the SDE/UUB/daq gitlab repository

SPMT calibration : spectra comparison method



Find the inter-calibration factor β , defined as


$$S_{SPMT} [VEM] = \beta Q_{SPMT} [FADC counts]$$

which minimizes the distance Δ between the LPMTs and SPMT signal spectra in a region of superposition where few LPMT signals are saturated, with


$$\Delta = \sum_{i=1}^{N_{bins}} \frac{(c_i^{LPMT} - c_i^{SPMT})^2}{c_i^{LPMT} + c_i^{SPMT}}$$

Details of the procedure in GAP2022_018 ([link](#))

Inter calibration precision




- ✓ β is updated every hour using **sliding intervals** of k hours to **follow the temperature variations**
- ✓ **k = 8 h**
trade-off between **precision (~2.2%)** and **correlation with temperature.**



Delay of LPMTs w.r.t. SPMTs

- Difference in the cable lengths:
 $l_{SPMT} = 2.45 \text{ m}$, $l_{LPMT} = 3.6 \text{ m}$ $\rightarrow 5\text{-}6 \text{ ns}$
- Purely due to photomultipliers (first dynode etc) measured for a couple of LPMT and SPMT in SDeCo (**thanks Juan Pablo!**)
 $\rightarrow 28\text{-}30 \text{ ns}$

blue = SPMT
pink = LPMT
yellow = trigger



Cross-calibration in CDAS-user & Offline

- ◆ SPMT cross-calibration added in the *IoSdCalibSPMT* class starting from **CDAS-user v6r4** (that is the version used in the latest ape releases).
- ◆ reproduced in the Offline class [*SmallPMTCalibData*](#)

name	definition
station ID, startTime, endTime	LS ID, start & end of the (8h) interval in GPS seconds excluding empty intervals longer than $dt = 180$ s dt based on small showers rate of ~ 0.055 Hz
uptime	
event_ratio	% of small showers with S_{LPMTs} avg. $> S_{min}$ and $Q_{SPMT} > 10$ FADC counts
β & $\delta(\beta) \times 4$	LPMTs avg. result + one value for each LPMT


When the cross-calibration is not available, the SPMT signal is not used in the SD reconstruction.

Thus no “SPMT bad periods” are needed at the moment.


SD event production v2r4

- ♦ New production v2r4 verified to give exactly the same results of Prod v2r0 (see presentation at CDAS call on 19/04/2023, [slides download](#)).


Difference between logarithmic SD energies




Difference between SD zenith angles




Difference between SD azimuth angles




Difference between logarithmic FD energies



Difference between FD zenith angles



Difference between FD azimuth angles



←
Differences
between
reconstruction
of Prod-v2r0
and Prod-v2r4
events

SPMT codes

- Small showers acquisition
 - Local station DAQ: [SDEU/UUB/daq](#)
 - CDAS-DAQ: [Apps/SPMT](#)
 - *example code to read small showers files: [spmt example](#)*
- [SPMT HV setting](#)
- Small showers acquisition monitoring (**running in Lyon**)
 - ▶ [calculation of 1h-averages](#)
 - ▶ [filling of the MonitSmallShowers table](#)
- [SPMT inter-calibration](#) (**running in Lyon**)
- SPMT inter-calibration inclusion in the SD files production (**running in Lyon**)
 - ▶ *IoSdCalibSPMT class in [IoSdData.h](#) & [IoSdData.cc](#)*
 - ▶ [SdExtraData.cc](#) & [SdExtraData.h](#)

Small showers acquisition monitoring

The screenshot shows the phpMyAdmin interface for the AugerMonitor database. The left sidebar lists various tables, with 'MonitSmallShowers' highlighted. The main area displays the structure of the 'MonitSmallShowers' table, which contains 43 variables. The table has columns for 'Campo' (Field), 'Tipo' (Type), 'Collation', 'Attributi' (Attributes), 'Null', 'Predefinito' (Default), 'Extra', and 'Azione' (Actions). Most fields are of type float(6,2) or smallint(5), with some being UNSIGNED. The 'Azione' column shows standard MySQL edit and delete icons.

Campo	Tipo	Collation	Attributi	Null	Predefinito	Extra	Azione
Time	datetime			No			
GPSsec	int(10)		UNSIGNED	No			
LsId	smallint(5)		UNSIGNED	No			
Events	smallint(5)		UNSIGNED	No			
EventsLPMT1	smallint(5)		UNSIGNED	No			
ChargeLPMT1overChargeSPMT	float(6,2)			No			
PeakLPMT1overPeakSPMT	float(6,2)			No			
SignalLPMT1overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT1	float(6,3)			No			
EventsLPMT2	smallint(5)		UNSIGNED	No			
ChargeLPMT2overChargeSPMT	float(6,2)			No			
PeakLPMT2overPeakSPMT	float(6,2)			No			
SignalLPMT2overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT2	float(6,3)			No			
EventsLPMT3	smallint(5)		UNSIGNED	No			
ChargeLPMT3overChargeSPMT	float(6,2)			No			
PeakLPMT3overPeakSPMT	float(6,2)			No			
SignalLPMT3overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT3	float(6,3)			No			
EventsLPMTsAvg	smallint(5)		UNSIGNED	No			
AreaOverPeakSPMT	float(6,3)			No			
AreaOverPeakSSDHG	float(6,3)			No			
AreaOverPeakSSDLG	float(6,3)			No			
CustomVEMChargeLPMT1	float(6,2)			No			
CustomVEMChargeLPMT1Failures	float(6,2)			No			
MaskedStatusLPMT1	float(6,3)			No			
ThresholdLPMT1	float(6,2)			No			
OnlineVEMChargeLPMT1	float(6,2)			No			
HgLgChargeRatioLPMT1	float(6,3)			No			
CustomVEMChargeLPMT2	float(6,2)			No			
CustomVEMChargeLPMT2Failures	float(6,2)			No			
MaskedStatusLPMT2	float(6,3)			No			
ThresholdLPMT2	float(6,2)			No			
OnlineVEMChargeLPMT2	float(6,2)			No			
HgLgChargeRatioLPMT2	float(6,3)			No			
CustomVEMChargeLPMT3	float(6,2)			No			
CustomVEMChargeLPMT3Failures	float(6,2)			No			
MaskedStatusLPMT3	float(6,3)			No			
ThresholdLPMT3	float(6,2)			No			
OnlineVEMChargeLPMT3	float(6,2)			No			
HgLgChargeRatioLPMT3	float(6,3)			No			
CustomMIP	float(6,2)			No			
CustomMIPFailures	float(6,2)			No			


43 variables - 24 entries per day per UUB tank

MonitSmallShowers table added to the AugerMonitor database

Daily and separately for each tank with a SPMT, one should check :



- ◆ presence of acquired data (i.e. [number of entries in the table](#));
- ◆ number of small showers ([Events](#));
- ◆ then, separately for each LPMT :
 - * masked status ([MaskedStatusLPMT1-2-3](#));
 - * percentage of failed VEM calibrations using the custom algorithm ([CustomVEMCharge LPMT1-2-3Failures](#));
 - * number of events above 200 VEM ([EventsLPMT1-2-3](#));
 - * LPMT signal over SPMT charge ratio ([SignalLPMT1-2-3over ChargeSPMT](#)).

Stable cross-calibration (example LsId 20)




Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.





SPMT in a good station
 $\sigma[\beta]/\beta < 4\%$
 $\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}]$
 $\sim 10-12\%$

Stable cross-calibration (example LsId 27)




Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.





SPMT in a good station
 $\sigma[\beta]/\beta < 4\%$
 $\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 10-12\%$

Deficit in the light at the SPMT (example Lsld 700)



Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.




When the light reaching the SPMT reduces...

$$\sigma[\beta]/\beta < 6\%$$



$$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 13-15\%$$

Deficit in the light at the SPMT (example Lsld 760)



Daily relative dispersion of β

Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.



When the light reaching the SPMT reduces...

$$\sigma[\beta]/\beta < 6\%$$

$$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 13-15\%$$